



NOTES:

1. THE LATERAL CHECK VALVE STATION SHALL BE LOCATED IN AN AREA APPROVED BY THE DISTRICT.
2. ALL JOINTS SHALL BE GLUED/SOLVENT WELD.
3. TRACE WIRE SHALL BE CONTINUOUS #8 COPPER WIRE WITH TWO FEET COILED IN BOX.
4. COVER OVER FORCE MAIN SHALL BE 36" UNLESS OTHERWISE APPROVED BY THE DISTRICT.

WEST BAY	
SANITARY DISTRICT	
1-1/4" LATERAL CHECK VALVE STATION	
APPROVED BY:	
TIMOTHY CLAYTON	4/18/2005
DISTRICT MANAGER	DATE:
	12