



NOTES:

1. TRACE WIRE SHALL BE SOLID AND COATED 8 GAUGE COPPER WIRE.
2. THE CONTRACTOR SHALL EXCAVATE BY HAND EXPOSING THE EXISTING PRESSURE SEWER MAIN.
3. THE CONTRACTOR SHALL COAT CONNECTION WITH CORROSION PROTECTION.

| | |
|---|-----------------------|
| WEST BAY SANITARY DISTRICT | |
| FORCEMAIN SERVICE CONNECTION | |
| APPROVED BY: /s/ - SERGIO RAMIREZ GENERAL MANAGER | DATE: 06-28-23 |
| 16 | |