



ELEVATION

NOTES:

- 1) SEE STANDARD MANHOLE DETAIL FOR MANHOLE CONSTRUCTION AND DIMENSIONS.
- 2) AN APPROVED WATER STOP SHALL BE INSTALLED ON ALL FLEXIBLE PIPE ENTERING OR EXITING MANHOLE.

<b>WEST BAY</b>	
SANITARY DISTRICT	
DROP MANHOLE DETAIL FOR CONNECTION OF EXISTING SEWER TO NEW MANHOLE	
APPROVED BY:	
/S/ - SERGIO RAMIREZ	06-28-23
GENERAL MANAGER	DATE: