



# West Bay Sanitary District Code of Safe Practice

FOR IMMEDIATE RELEASE  
Initial: June 01, 2012

Questions or comments regarding this  
Code of Safe Practice should be directed  
to the Regulatory Compliance Coordinator.

## Generators

- Do not run engine in an enclosed area.
- Do not run engine at excessive speeds.
- Do not check for spark with spark plug or removed spark plug wire. Use an approved tester.
- Do not tamper with governor springs, governor links or other parts which may increase the governed engine speed.
- Do not operate engine without a muffler.
- Do not touch hot muffler, cylinder, or fins as contact may cause burns.
- Do not refuel indoors when area is not well ventilated.
- Do not operate engine with an accumulation of grass, leaves, dirt or other combustible material in the muffler area.
- Do not run engine with air cleaner or air cleaner cover removed.
- Follow proper maintenance schedule.
- Do not place hands or feet near moving or rotating parts.
- Do not operate engine if diesel fuel is spilled.
- Do not operate engine when an odor of diesel fuel is present or other explosive conditions exist.
- Keep cylinder fins and governor parts free of grass and other debris.

### PERSONAL PROTECTIVE EQUIPMENT

Protection Area	PPE Required
Eye	Safety glasses with side shields or goggles meeting the ANSI Z87.1 Standard.
Face	
Hand	Work gloves when necessary.
Head	Hardhat as necessary.
Foot	Leather steel toe safety shoes or boots.

Body	
Respiratory	
Hearing	Wear earplugs or earmuffs as necessary.