



NOTES:

1. THE LATERAL CHECK VALVE STATION SHALL BE LOCATED IN AN AREA APPROVED BY THE DISTRICT.
2. ALL PVC JOINTS SHALL BE GLUED/SOLVENT WELD.
3. TRACE WIRE SHALL BE CONTINUOUS 8 GAUGE SOLID AND COATED COPPER WIRE WITH TWO FEET COILED IN BOX.
4. COVER OVER FORCE MAIN SHALL BE 36" UNLESS OTHERWISE APPROVED BY THE DISTRICT.
5. ALL PIPINGS SHOULD BE PVC SCHEDULE 80 OR HDPE SDR11.

WEST BAY SANITARY DISTRICT	
1-1/4" LATERAL CHECK VALVE STATION	
APPROVED BY:	
/s/ - PHIL SCOTT	06-24-15
DISTRICT MANAGER	DATE:
	12