



NOTES:

1. TRACE WIRE SHALL BE CONTINUOUS COATED #8 WIRE.
2. THE CONTRACTOR SHALL EXCAVATE BY HAND EXPOSING THE EXISTING PRESSURE SEWER MAIN.
3. THE CONTRACTOR SHALL COAT CONNECTION WITH CORROSION PROTECTION.

WEST BAY	
SANITARY DISTRICT	
FORCEMAIN SERVICE CONNECTION	
APPROVED BY:	
/s/ - PHIL SCOTT	06-24-15
DISTRICT MANAGER	DATE:
16	