



NOTES:

1. Pump shall be Environment One Model DH151-74 with poured-in-place concrete anchor. (2773 Balltown Road, Schenectady, NY 12309-1090. (518) 346-6161, Fax (518) 346-6188. Local Representative: Signa Mechanical (949) 548-1125).
2. Pump shall be installed per manufacturer's recommendations.
3. See Single Family Grinder Pump Information Detail for pump anchor detail.
4. See 1-1/4 Inch Lateral Check Valve Station Detail for discharge line valve requirements.
5. Contractor shall supply District with handle to turn PVC ball valve.
6. Control Panel (supplied by ISAC (per West Bay Detail #17)).
7. If the homeowner has an on-site pump system that pumps into the grinder pump, the homeowner shall notify the District when applying for permit. Additional requirements specific to the project will be applied.
8. Owner shall provide a spare grinder pump to the District.

WEST BAY	
SANITARY DISTRICT	
SINGLE FAMILY GRINDER PUMP INSTALLATION DETAIL	
APPROVED BY:	
/S/ - PHIL SCOTT	06-24-15
DISTRICT MANAGER	DATE: