


SEMI-POSITIVE DISPLACEMENT TYPE PUMP
DIRECTLY DRIVEN BY A 1 HP MOTOR
CAPABLE OF DELIVERING 9 gpm AT 138' T.D.H.

NOTE:

1. Pump shall be Environment One Model DH151-74 with poured-in-place concrete anchor. (2773 Balltown Road, Schenectady, NY 12309-1090. (518) 346-6161, Fax (518) 346-6188. Local Representative: Signa Mechanical (949) 548-1125. OWNER SHALL PROVIDE A SPARE PUMP TO THE DISTRICT.

FILL TO GRADE WITH CLEAN, COMPACTABLE BACKFILL, SUCH AS PEA GRAVEL OR CRUSHED STONE, 1/8" - 3/4" IN SIZE. CLAY AND SILTS ARE NOT ACCEPTABLE BACKFILL



POURED-IN-PLACE CONCRETE ANCHOR DETAIL

WEST BAY
SANITARY DISTRICT

SINGLE FAMILY
GRINDER PUMP INFORMATION DETAIL

APPROVED BY:

/s/ - PHIL SCOTT

DISTRICT MANAGER

06-24-15

DATE:

20